

Certified translation from the German

GARRISON ADMINISTRATION OF WALLDÜRN
IV 2.2.010 file number: 45- 01- 11

Walldürn, 23 October 1995
Federal forces trunk dialing number 5726
Telephone (06282) 5 11 (EXT)
Fax (06282) 5 11 / 4 95
Clerk in charge: H. Gremminger

Gesellschaft für Ing. Projekte GIF mbH
Brühlstr. 7
79112 Freiburg-Opfingen

Dear Sirs,

Damage caused by fire in the mess kitchen
Building No. 11 - Nibelungen Barracks Walldürn

On 25 October 1993, a deep-frying pan, rated capacity 28 KW, caught fire in the mess kitchen in building No. 11 in the Nibelungen barracks Walldürn.

A ventilation ceiling with modular grid dimensions 500/500 mm, "make GIF" is installed above the cooking appliances.

The fire caused damage to several coffers as a result of burning fat. Nevertheless, the suspension device has not been damaged by the fire and withstood fire exposure for about 40 - 50 minutes.

By order
(signature illegible)
(Gremminger)

Mailing address: P.B.O. 1431 , 74726 Walldürn
Office: Waldstrasse 6 , 74731 Walldürn

I hereby certify that the above text is a true and correct translation of the original German document/certified copy submitted:

- 8 MAR 2001

Freiburg, dated: _____

(Sworn translator)

